

Kiwa Italia S.p.a.

Sede Legale:

Via C. Goldoni, 1 - 20129 Milano (MI)

Sede Amministrativa:

Via Treviso, 32/34 - 31020 San Vendemiano (TV)
Tel. +39 0438 411755 - Fax +39 0438 22428

Internet: www.kiwa.it - E-mail: info@kiwa.it

DECLARATION REGARDING VOKERA Ltd

Test performed on LPG/NG see note below	Original Boiler Name	UK Market Name	Full Load Efficiency (% net)	Part Load Efficiency (% net)
NG	Mynute i20	Mynute i20	97,6	108,8
LPG	Mynute i20	Mynute i20	96,6	104,5
NG	Mynute i30	Mynute i30	97,5	108,6
LPG	Mynute i30	Mynute i30	96,6	106,8

We declare that the full and part load efficiency test results detailed above have been obtained by means deemed to satisfy the Boiler Efficiency Directive (92/42/EEC). The water temperature criteria defined in the Boiler Efficiency Directive (see below) have been satisfied in obtaining these results.

Type of Boiler	Range of Power	Efficiency at rated output	Efficiency at part load
	KW	Average boiler-water temperature	Average boiler-water temperature
Standard boilers	4 to 400	70° C	≥ 50° C
Low temperature boilers ¹	4 to 400	70° C	40° C
Gas condensing boilers	4 to 400	70° C	30° C ²

¹ Including condensing boilers using liquid fuels.

² Temperature of boiler water supply.

San Vendemiano, 21/10/2014

Kiwa Italia Spa.



Mariella Pozzoli
President