



Number	KIP-15057/G	Replaces	---
Issued	17-05-2016	Scope	Directive 2009/142/EC
Report	151000857/2	Page	1 of 1
PIN	0476CQ0857		

## EC TYPE EXAMINATION CERTIFICATE

**Kiwa Cermet Italia hereby declares that the products**  
Central heating condensing boilers

Trade mark: **VOKERA**

Models: **MAXIM 25**  
**MAXIM 29**

Manufactured for: **VOKERA Ltd**  
London Colney, Great Britain

meet the essential requirements as described in the  
**Directive on appliances burning gaseous fuels 2009/142/EC**

Mentioned products have been approved for

Appliance type: **B<sub>23P</sub>, B<sub>53P</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>, C<sub>63</sub>, C<sub>83</sub>, C<sub>93</sub>,**  
**C<sub>13x</sub>, C<sub>33x</sub>, C<sub>43x</sub>, C<sub>53x</sub>, C<sub>63x</sub>, C<sub>83x</sub>, C<sub>93x</sub>**

Countries: **AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB,**  
**GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT,**  
**RO, SE, SI, SK, TR**

Related to the following gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	Esi	20/25	P	30; 37; 50
H	20;25	M	20		


*The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.*

The assessment test have been performed using the following standards as guidelines:

EN 483:1999  
EN 483/A2:2001  
EN 483/A4:2007  
EN 483/AC:2006  
EN 677:1998


*The validity of this certificate can be verified by means of a register available on the website [www.kiwa.it](http://www.kiwa.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia*

Chief Operating Officer  
Giampiero Belcredi



**kiwa**  
Approved

EC Directive



2009/142/EC

G A S T E C



Organismo Notificato n. 0476

Certificate

**Kiwa Cermet Italia S.p.A.**  
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)

Unità locale  
Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)

[www.kiwa.it](http://www.kiwa.it)  
[www.kiwacermet.it](http://www.kiwacermet.it)

**G A S T E C**



Number	KIP-15057/E	Replaces	---
Issued	17-05-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	151000857/2	Page	1 of 2
PIN	0476CQ0857		

## EC TYPE EXAMINATION CERTIFICATE

**Kiwa Cermet Italia, notified body for council Directive 92/42/EEC, hereby declares that according to article 4 of commission regulation (EU) No. 813/2013 the products**

Central heating condensing boilers

Trade mark: **VOKERA**

Models: **MAXIM 25  
MAXIM 29**

Manufactured for: **VOKERA Ltd**  
London Colney, Great Britain

Have achieved the following (see Annex 1) full and part load efficiencies.

The assessment test have been performed using the following standards as guidelines:

- EN 483:1999
- EN 483/A2:2001
- EN 483/A4:2007
- EN 483/AC:2006
- EN 677:1998

*The validity of this certificate can be verified by means of a register available on the website [www.kiwa.it](http://www.kiwa.it)  
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia*

**Kiwa Cermet Italia S.p.A.**  
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)

**Unità locale**  
Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)

[www.kiwa.it](http://www.kiwa.it)

[www.kiwacermet.it](http://www.kiwacermet.it)


**GASTEC**

Chief Operating Officer  
Giampiero Belcredi



SGQ N° 007A SSI N° 006G  
SGA N° 010D FSM N° 004I  
PRD N° 069B

**kiwa**  
Approved



92/42/EEC

G A S T E C



Organismo Notificato n. 0476



Number	KIP-15057/E	Replaces	---
Issued	17-05-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	151000857/2	Page	2 of 2
PIN	0476CQ0857		

## EC TYPE EXAMINATION CERTIFICATE

### ANNEX 1

#### Models:

	MAXIM 25	MAXIM 29
$\eta_{100}$	97,8 %	98,0 %
$\eta_{30}$	108,9 %	108,4 %
$\eta_4$	88,1 %	88,2 %
$\eta_1$	98,1 %	97,6 %
$P_4$	19,5 kW	24,5 kW
$P_1$	n.t.	n.t.
C.Heater?	Yes	Yes
B <sub>1</sub> Boiler?	No	No
Type of boiler:	Condensing	Condensing

#### Note:

$\eta_{100}$  = At rated heat output and high-temperature regime - NCV (\*)

$\eta_{30}$  = At 30 % of rated heat output and low-temperature regime - NCV (\*\*)

$\eta_4$  = At rated heat output and high-temperature regime - GCV (\*)

$\eta_1$  = At 30 % of rated heat output and low-temperature regime - GCV (\*\*)

$P_4$  = At rated heat output and high-temperature regime (\*)

$P_1$  = At 30 % of rated heat output and low-temperature regime (\*\*)

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B<sub>1</sub> Boiler = B<sub>1</sub> according CEN/TR 1749:2014

Type of boiler = "Condensing Boiler" or "Low Temperature Boiler" or "Other Boiler"

Efficiency's values have been measured with gas G20.

(n.t.= not tested)

Certificate

Kiwa Cermet Italia S.p.A.

Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23  
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34  
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: [info@kiwacermet.it](mailto:info@kiwacermet.it)

[www.kiwa.it](http://www.kiwa.it)

[www.kiwacermet.it](http://www.kiwacermet.it)

**GASTEC**

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).